

Cert. No. DNV\_GL-2018-RGRC\_FTC-001-A

Client :EUROGUARCO S.p.A.Address :Via Terralba 9, Loc. Pietralba - 19021 Arcola (La Spezia) - ItalyDate of test :27 July 2018

### We hereby declare that,

at request of Messrs **EUROGUARCO S.p.A.** the undersigned GLIS Surveyor did attend at the their Plant located in Via Leonardo da Vinci 6 A/B - 26020 Ticengo (CR) - Italy on date 27 July 2018, for the purpose of witnessing the FIRE TEST on the following valve according to API 6FA Ed.2018.

## BALL VALVE SIDE ENTRY TRUNNION 2" Class 300lbs - Carbon Steel

Enclosed is a sectional drawing of the valve under test complete with a list of materials : Drawing / Figure N° : **2945-02-18-BA-001** 

The following tests were carried out:

- The valve was subjected to full hydrostatic (water) and gas tests at ambient temperature with Satisfactory results. Tests were in accordance with API 6D 24<sup>th</sup> Edition 2014.
- 2-) The valve was fire tested according to API 6FA Ed.2018.
- 3-) The valve was completely disassembled and all components were found in good conditions with exception of the Soft Seat and Soft Seals that were damaged.
- 4-) Herewith attached and duly endorsed the following documents : Fire Test Report N° : FS-2-300-02 Drawing / Figure N° : 2945-02-18-BA-001

### **CONCLUSION :**

On the basis of test results the **BALL VALVE SIDE ENTRY TRUNNION 2" Class 300lbs -Carbon Steel** passed satisfactorily the fire safe test.



DNV GL Headquarters, Veritasveien 1, P.O.Box 300, 1322 Høvik, Norway. Tel: +47 67 57 99 00. www.dnvgl.com



Cert. No. DNV\_GL-2018-RGRC\_FTC-002-A

Client :EUROGUARCO S.p.A.Address :Via Terralba 9, Loc. Pietralba - 19021 Arcola (La Spezia) - ItalyDate of test :27 July 2018

### We hereby declare that,

at request of Messrs **EUROGUARCO S.p.A.** the undersigned GLIS Surveyor did attend at the their Plant located in Via Leonardo da Vinci 6 A/B - 26020 Ticengo (CR) - Italy on date 27 July 2018, for the purpose of witnessing the FIRE TEST on the following valve according to API 6FA Ed.2018.

## BALL VALVE SIDE ENTRY TRUNNION 16" Class 300lbs - Carbon Steel

Enclosed is a sectional drawing of the valve under test complete with a list of materials : Drawing / Figure N° : **2945-02-18-BA-002** 

The following tests were carried out:

- The valve was subjected to full hydrostatic (water) and gas tests at ambient temperature with Satisfactory results. Tests were in accordance with API 6D 24<sup>th</sup> Edition 2014.
- 2-) The valve was fire tested according to API 6FA Ed.2018.
- 3-) The valve was completely disassembled and all components were found in good conditions with exception of the Soft Seat and Soft Seals that were damaged.
- 4-) Herewith attached and duly endorsed the following documents : Fire Test Report N° : FS-16-300-03 Drawing / Figure N° : 2945-02-18-BA-002

#### **CONCLUSION:**

On the basis of test results the **BALL VALVE SIDE ENTRY TRUNNION 16**" Class 300lbs - Carbon Steel passed satisfactorily the fire safe test.



DNV GL Headquarters, Veritasveien 1, P.O.Box 300, 1322 Høvik, Norway. Tel: +47 67 57 99 00. www.dnvgl.com



Scegli la certezza. Aggiungi valore.

# FIRE SAFE TEST CERTIFICATE

Valve Type: SIDE ENTRY BALL VALVE 6" CLASS 600 FERRITIC MATERIAL To Drawing N° 721-12-11-BA-035 rev.0 Date: 26/09/2013

CERTIFICATE NUMBER: IS-240262-56-14



REPORT NUMBER: N° 01/11/2014 721-12-11-BA-035

<u>SCOPE OF REPORT:</u> Fire Safe test carried out according to Client procedure API SPECIFICATION 6FA Third Edition, April 1999 API STANDARD 607 Sixth Edition, September 2010 BS - UNI EN ISO 10497:2010

max bar:	75,3

max °C: 852



Direzione e Sede Amministrativa: Via Giosué Carducci, 125 edificio 23 20099 Sesto San Giovanni (MI) Sede legale: Via Mauro Macchi, 27 20124 Milano Società soggetta al controllo e al coordinamento di TÜV SÜD AG CERTIFICATION DATE

03/12/2014

Telefono: +39 02 24130.1 Telefax: +39 02 24130.399

www.tuv.it

MANAGEMENT OF 2 **VITTORIO FARINONI** TÜV Ce BUD Italia

Registro delle imprese di Milano n. iscrizione e Cod. Fisc. 08922920155 R.E.A. 1255140 - P. IVA 02055510966 Capitale sociale : Euro 500.000 int. vers. Coord. Bancarie: INTESA BCI - CIN J cć. 000018978166 - ABI 03069 - CAB 32934 IBAN: IT34 J030 6932 9340 0001 8978 166 TÜV ITALIA S.R.L. TÜV SÜD Group Via Giosuè Carducci, 125 edificio 23 20099 Sesto San Giovanni (MI) Telefono: +39 02 24130.1 Telefax: +39 02 24130.399 www.tuv.it



### FIRE SAFE TECHNICAL REPORT

FIRE SAFE CERTIFICATE N°: IS-240262-56-14

<u>REPORT N°:</u> N° 01/11/2014 721-12-11-BA-035

CLIENT: EUROGUARCO S.p.A.

ADDRESS: VIA TERRALBA, loc. PIETRALBA – 19021 ARCOLA (SP) - ITALY

QUALIFIED VALVE		
VALVE SIZE:	6"	
VALVE RATING CLASS:	600	
DRAWING N°:	N. 721-12-11-BA-035 rev.0	
VALVE TIPE:	SIDE ENTRY BALL VALVE 6" CLASS 600 FERRITIC MATERIAL	
MAX bar:	<u>75,3</u>	
MAX °C:	<u>852</u>	

RANGE AND TYPE OF	NPS: 6; 8; 10; 12 (API 6D) 71/16; 9; 11 (API 6A) - DN: 150; 200; 250; 300 (for API 6FA)
VALVES COVERED:	NPS: 6; 8; 10; 12 - DN: 150; 200; 250; 300 (ISO 10497 and API 607) CLASS: 600; 900 (API 6D) 2000; 3000 (API 6A) - PN 110; 150 (for API 6FA)
	CLASS: 600; 800; 900 - DN: 100; 150 (ISO 10497 and API 607)

THE ABOVE MENT	THE ABOVE MENTIONED VALVE SUCCESSFULLY PASSED THE FIRE SAFE		
	ACCORDANCE TO:		
	API SPECIFICATION 6FA Third Edition, April 1999		
	API STANDARD 607 Sixth Edition, September 2010		
	BS - UNI EN ISO 10497:2010		

<u>NOTES:</u>	
LOCATION AND DATE OF TEST CARRIED OUT:	At CO.MA.IS s.a.s - Via Marelli, 70 - 20043 Cerro Maggiore (MI) - 28/11/2014
TÜV INSPECTOR	Tederici.



Cert. No. DNV\_GL-2017-RGRC\_FTC-001-A

Client :EUROGUARCO S.p.A.Address :Via Terralba 9, Loc. Pietralba - 19021 Arcola (La Spezia) - ItalyDate of test :09 November 2017

### We hereby declare that,

at request of Messrs **EUROGUARCO S.p.A.** the undersigned GLIS Surveyor did attend at the their Plant located in Via Leonardo da Vinci 6 A/B - 26020 Ticengo (CR) - Italy on date 09 November 2017 for the purpose of witnessing the FIRE TEST on the following valve according to API 6FA Ed.1999.

## BALL VALVE SIDE ENTRY TRUNNION 2" Class 600lbs - Carbon Steel

Enclosed is a sectional drawing of the valve under test complete with a list of materials : Drawing / Figure  $N^{\circ}$  : **FS-2-600-01** 

The following tests were carried out:

- The valve was subjected to full hydrostatic (water) and gas tests at ambient temperature with Satisfactory results. Tests were in accordance with API 6D 24<sup>th</sup> Edition 2014.
- 2-) The valve was fire tested according to API 6FA Ed.1999.
- 3-) The valve was completely disassembled and all components were found in good conditions with exception of the Soft Seat and Soft Seals that were damaged.
- 4-) Herewith attached and duly endorsed the following documents : Fire Test Report N° : FS-2-600-01 Drawing / Figure N° : FS-2-600-01

### CONCLUSION

On the basis of test results the **BALL VALVE SIDE ENTRY TRUNNION 2" Class 600lbs** -Carbon Steel passed satisfactorily the fire safe test.



DNV GL Headquarters, Veritasveien 1, P.O.Box 300, 1322 Høvik, Norway. Tel: +47 67 57 99 00. www.dnvgl.com